

Certificate of constancy of performance



Number	0063-CPR-104552/03	Replaces	0063-CPR-104552/02
Issued	01/05/2022	First issued	19/05/2020

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Manually operated ball valves for gas installations

whereby the scope of construction product(s) is listed on page 2 of this certificate placed on the market under the name or trademark of

FLEXUM Ball valve

and produced in the manufacturing plant
STROHM MOFÉM Zrt.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 331:1998/A1:2010

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **19-05-2020** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers
Kiwa
Managing Director

Advise: consult www.kiwa.com to check whether the certificate is valid.

562/200504

CERTIFICATE

Notified Body No. 0063
Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 (0) 88 998 44 00
Fax +31 (0) 88 998 44 20
info@kiwa.nl
www.1kiwa.com




Manufacturer
STROHM MOFÉM Zrt.
H-2900 Mosonmagyaróvár
Hungary

T : +36 96 574-517
www.mofem.hu / www.strohm-teka.com



Certificate of constancy of performance



0063-CPR-104552/03

Manually operated ball valves for gas installations

SCOPE

Type	DN	Connection	Temp. class / MOP	Temp. resistance class
FLEXUM Ball valve 15	15	1/2"	-5 °C / 5 bar	A
FLEXUM Ball valve 20	20	3/4"	-5 °C / 5 bar	A
FLEXUM Ball valve 25	25	1"	-5 °C / 5 bar	A